

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-0785:151 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Wheelock Inc., 273 Branchport Avenue, Long Branch, NJ 07740
Contact: Luy Nguyen (732) 222-6880 Fax (732) 222-5607

DESIGN: Models CH70-24MCW, CH70-24MCC, *CH70-24MCWH, *CH70-24MCCH, CH90-24MCW, CH90-24MCC, *CH90-24MCWH, and *CH90-24MCCH, synchronized or non-synchronized multi-candela chime strobes. Units may be followed by suffixes to designate lens orientation, lens lettering and plate color. Models with suffix -W or *WH are wall mount, -C or *CH are ceiling mount. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

Electrical:	6-33 VDC
Flash rate:	60 flashes/min
Candela:	Selectable:
	*MCW = 15cd, 30cd, 75cd or 110cd
	*MCC = 15cd, 30cd, 75cd or 95cd
	*MCWH = 135cd, 185cd
	*MCCH = 115cd, 177cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction. *For indoor use on a wall or ceiling.

MARKING: Listee's name, model number, electrical/candela rating, and UL label.

APPROVAL: Listed as chime strobes suitable for the hearing impaired when used in conjunction with separately listed electrically compatible fire alarm control units. For synchronized strobes, Models SM-12/24, SMX-12/24, DSM-12/24, DSMX-12/24 or SCM-24 sync control module must be used. Refer to listee's Installation Instruction Manual for details.

*Rev. 02-13-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 13, 2004**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**